

STOHS 02100 / 02200 / 02300 STOHS 03100 / 03200 / 03300 STOHS 04100 / 04200 / 04300 STOHS 06100 / 06200 / 06300



DATA SHEET

rev. 3.1 28 August 2024

Kernel Sistemi Kernel Sistemi s.r.l., via Vignolese n. 1138 41126 Modena - ITALY Tel. 059 469 978 - Fax 059 468 874 www.kernelgroup.it

INDEX

1	SAFETY	
2	GENERAL NOTES	4
2.1	Introduction	4
	HARDWARE CHARACTERISTICS	
3.1	Hardware Characteristics.	6
3.2	Board Dimensions	7
	Connectors	
3.4 3.5		
3.5 3.6		
3.7		
3.8		
3.9		
	Fixing system of the naked board (without supporting box)	
3.11		
	2 RS485 Communication cable	
	Informations about wires and connectors	
4	MEMORY MAP	12
	Memory Map Description	
5	ORDER CODES	16
6	CONTACTS	17

Attention

The information contained in this document may change without notice.

Therefore, please check our website (<u>www.kernelgroup.it</u>) regularly

and always download the latest version available.

1 SAFETY

This product is a String Monitoring System (SMU) and its application is the monitoring of photovoltaic systems. From an electrical point of view, by their nature, photovoltaic systems operate in direct current and with very high voltage and current values.

DANGER - This product is therefore designed to operate with direct current voltage values up to 1500 VDC. This voltage value is potentially fatal. Voltage values between 24 VDC and 1500 VDC are therefore present on this product. - All transducers connected to the auxiliary input connectors must be isolated at 1500 VDC. These transducers are PT100 and, in the case of the ST2N and ST2 series, also transducers with 0/10 VDC and 0/20 mA output (typically anemometers)

Safety: Installation and replacement precautions					
	DANGER	- The installation and / or replacement of this product must take place in absolute safety, therefore it is necessary to proceed with the installation and / or replacement of this product which is housed inside the field panel after disconnecting the power and dangerous voltages from solar panels.			
		- In any case, any intervention involving the handling of the SMU must be carried out by skilled and trained technicians equipped with insulation gloves designed for voltage values up to 1500 VDC and after disconnecting any voltage and current from the solar panels.			

	Important Safety Instructions				
DANGER		- Contact with wiring terminals inside the device can cause death by electric shock! - Before to operate inside cards with tester, or with other measurement equipment, it is mandatory TO OPEN fuses and other components that can bring high level voltage inside cards.			
<u> </u>	WARNING	 Please check all input and output wire terminals in case of high DC voltage and make sure there is no voltage before electrical connection to avoid electric shock! Do not touch the live parts of the input and output sides to avoid electric shock when checking or maintaining the device. All installation and wiring connections must be made by qualified technical personnel only. 			
A	CAUTION	 All wiring and operation must comply with the requirements of the relevant local standards of the device. Check the device and make sure there are no problems with the installation before putting it into operation! Connect the wires to the positive and negative marked positions of the device to avoid the risk of short circuit, ensure personal safety and keep the device in normal operation. 			
•	IMPORTANT	Reference to current standards For any other consideration, safety precaution, it is absolutely necessary, before carrying out any installation and / or replacement of the SMU, to refer to the regulations in force regarding the construction of combiner boxes.			

2 GENERAL NOTES


2.1 Introduction


The STOHS module to string control, allow to monitoring current and voltage generated by photovoltaic panels strings. When the current will be measured goes through a sensor, the voltage will be measured at the output end.

The STOHS board also provides two digital inputs and an on-board sensor which allow to measure the temperature. The digital inputs allows to detect the arrester state and the power disconnector switch state.

Is possible communicate with the STOHS board through a RS485 serial port. Using **Modbus RTU protocol**, or with **IEC 60870-5-101 protocol**, is possible monitoring all the physical quantities measured (temperature, currents, voltage). Moreover is possible keep monitored the fuses status on the string box, through the reading of an internal register on memory map (30034).

In the following image there are the "STOHS string controller" with all the wiring. Obviously isn't necessary connect all the specified devices, they are indicated to give a connection general idea.





3 HARDWARE CHARACTERISTICS

3.1 Hardware Characteristics

ELECTRIC CHARACTERISTICS					
Microprocessor	STM32F303				
Power supply			24	Vdc	
Power consumption (W)			< 2	2 W	
Maximum number of monitored strings	2		3	4	6
Maximum common voltage		1500 V	/ with precision	on better than 0,5 %	
Max. current for each string	100 A 200 A 300 A		100 A 200 A 300 A	100 A 200 A 300 A	100 A 200 A 300 A
Range of measurement	0 200 / 400 / 600 A	300 /	0 600 / 900 A	0 400 / 800 / 1200 A	0 600/ 1200 / 1800A
Current reading accuracy			Better th	nan 0,5 %	
Current reading precision			Better th	nan 1,5 %	
Communication	RS4	85 / RS	487 (Modbus I	RTU or IEC 60870-5-1	01)
Digital Inputs			2 digital inpu	ts 24 Vdc PNP	
Analog inputs	1 input PT100 + 1 on	board		sensor to know the ter ox panel	mperature inside the
Working temperature's range			From -40	to +85 °C	
Working atmosphere			Without co	orrosive gas	
ID Address			Defined by	dip-switches	
Size (naked)	279,7 x 108 mm	279,	7 x 108 mm	279,7 x 108 mm	338 x 108 mm
Size (with support for din rail bar)	283,7 x 128 mm	283,7 x 128 mm 283,7 x 128 mm		283,7 x 128 mm	342 x 128 mm
Working humidity		Lo	wer 95 % with	out condensation	
MTBF	> 500000 hours				
Maximum Operating Altitude	4000 meters				
Minimum Current	1 A (programmable) from Firmware Version:			sion :	
Minimum Voltage	100 V (programmable) 1.31 forward				

N°	Type of resources	Symbol	Terminal Block
1	Sensor on board to read the temperature (precision better than 1,5 %)	Т2	On board
1	RS485 serial port. This serial port is used to connect many "STOHS string controllers" into a network or to a PC. Is possible select the communication characteristics with some dip-switches on board (node address, baud rate, parity, and communication protocol, that may be Modbus RTU or IEC 60870-5-101). This COM is divided in two connectors in order to facilitate the wiring	SERIAL PORT	CN2
1	PT100 input (from -20 to +120 $^{\circ}\text{C})$ to temperature reading, with precision better than 1,5 $\%$	T1	CN4
2	PNP digital inputs 24 Vdc, typically used to arrester connection, switches or other devices	INPO, INP1	CN4


www.kernelgroup.it Kernel Sistemi s.r.l.

2 3 4 6	This board can manage the current reading of 2/4/6 strings until 100 A / 200 A with typical precision of 1.5 % and a temperature between -20 and +80 $^{\circ}\text{C}$	Ch1Ch2 Ch1Ch3 Ch1Ch4 Ch1Ch6	Hall Sensors
------------------	---	--------------------------------------	--------------


3.2 Board Dimensions

Maximum number of monitored strings	2	3	4	6
Size (naked)	279,7 x 108 mm	279,7 x 108 mm	279,7 x 108 mm	338 x 108 mm
Size (with support for din rail bar)	283,7 x 128 mm	283,7 x 128 mm	283,7 x 128 mm	342 x 128 mm

3.3 Connectors




3.4 Connector: CN1



3.5 Connector: CN2


On connector CN2 there is a split serial port RS485, 3 wires: plus, minus and GND. You need to connect these three wires to the converter USB/RS485. The connector's pins which must be connected are pin 6 (GND), 5 (-) and 4 (+):



There are bridges inside cards to make easy cabling of RS485.


- Pin 1 is connected inside PCB to pin 4
- Pin 2 is connected inside PCB to pin 5
- Pin 3 is connected inside PCB to pin 6

It's possible to enter with 3 cables RS485 using pin 1,2,3 and exit with RS485 cables using pin 4,5,6:



3.6 Connector: CN3


To read the voltages, is necessary connect the negative cable to pin "-" and the positive cable to the pin "+" of connector CN3. You'll find the voltage value on 30040 (instant value) or 30084 (average value on last 6 seconds).




3.7 Connector: CN4

To know when a switch (for example the general one) is ON or OFF, there are two digital inputs PNP 24 Vdc on terminal block CN4. Each digital input status is indicated also by a led status on board. You need to use the pins 5, 6, 7 and 8. Inside the memory map the bits from 0 to 1 of register 30001 are the digital input status.

Is possible connect one PT100 to read the external temperature. The PT100 could be 2 or 3 wires, it will be connected as shown in the figure above to terminal block CN4. You can find this temperature on register 30044.




3.8 Dip-switches



Note: Parity = NO_PARITY; Bit = 8; Stop = 1

Some dip-switches examples:



3.9 Memory Protection

Memory is always protected by writing! In order to enable writing for a limited time (10 minutes), you have to write:

Value: 0x5555 Hex Modbus Register: 40100

3.10 Fixing system of the naked board (without supporting box)

To fix the naked board (without case) is necessary use plastic spacers with dual clutch. The plastic spacers must be 4x20 mm or 4x25 mm (4 mm is the hole diameter on the board). Look the below picture.



3.11 Status led

On the board there is a status led which with its blinking show the board status.

There are two possible different blinking ways: blinking each 0,5 sec, or blinking faster. If the blinking is 0,5 sec ON and 0,5 sec OFF, it means that the board is ready to communicate with an external device, instead if the blinking is faster than 0,5 sec, it means that the board is in test mode with all the dip-switch OFF. In this way the board isn't ready to communicate with an external device.

3.12 RS485 Communication cable

Everything about the RS485 connection, must meet certain features:

Maximum cable length

it must be no longer than 1,2 Km (it means the entire line length, and not the connection between two nodes)

Maximum number of slaves


it's possible connect up to a maximum of one hundred slaves

Technical characteristics of the cable to use

It must be a three-wire cable 3 x 0.75 mm

How to do the RS485 connection

The RS485 connection must be a three wires connection (TX+, TX- and GND) with a shielded cable. The cable shield must be leaved float, it means that the shield must be not connected neither one side nor the other one.




3.13 Positive Current Values


IMPORTANT

To have POSITIVE CURRENT VALUES, you must insert the cables into the Hall sensors in one of the following ways:

IF YOU USE THE "+" [POSITIVE] CABLE Insert the cable from the BOTTOM to the TOP :



IF YOU USE THE "-" [NEGATIVE] CABLE Insert the cable from the TOP to the BOTTOM:



IMPORTANT

3.14 Informations about wires and connectors



CURRENT SENSOR				
Hole diameter	16 mm			
Operating temperature	-40°C ÷ +85°C			



OTHER CONNECTORS (Power Supply, Serial)			
Wire Range	2.5 mm² / 0.34-2.5 mm²		
Wire Strip length	7 - 8 mm		
Solid Wire (AWG)	12-24 / 14-22		
Screw	M3		
Max Torque	0.56 Nm [5.0 Lbf-In]		
Operating temperature	-40°C ÷ +115°C		



VOLTAGE CONNECTOR			
Wire Section	2.5 mm ² / 0.20-2.5 mm ²		
Stripping length	7 mm		
Conductor cross section AWG/kcmil	24 to 12		
Screw	M3		
Min / Max Torque	0.50 Nm / 0.60 Nm [4.4 Lbf-In / 5.3 Lbf-In]		
Operating temperature	-40°C ÷ (depends on the derating curve)		

4 MEMORY MAP

The STOHS has the following memory map, it's made of 16 bits locations (1 word) called "REGISTERS". Because each REGISTER is composed by 16 bits, its maximum value will be 65535.

Max. current for eac	h string	100 A	200 A	300 A	
MODBUS Register TYPE		DESCRIPTION			
30001	RO	Inputs			
30002	RO	Inst Curr Str_01 (A / 10 [01000])	Inst Curr Str_01 (A / 10 [02000])	Inst Curr Str_01 (A / 10 [03000])	
30003	RO	Inst Curr Str_02 (A / 10 [01000])	Inst Curr Str_02 (A / 10 [02000])	Inst Curr Str_02 (A / 10 [03000])	
30004	RO	Inst Curr Str_03 (A / 10 [01000])	Inst Curr Str_03 (A / 10 [02000])	Inst Curr Str_03 (A / 10 [03000])	
30005	RO	Inst Curr Str_04 (A / 10 [01000])	Inst Curr Str_04 (A / 10 [02000])	Inst Curr Str_04 (A / 10 [03000])	
30006	RO	Inst Curr Str_05 (A / 10 [01000])	Inst Curr Str_05 (A / 10 [02000])	Inst Curr Str_05 (A / 10 [03000])	
30007	RO	Inst Curr Str_06 (A / 10 [01000])	Inst Curr Str_06 (A / 10 [02000])	Inst Curr Str_06 (A / 10 [03000])	
•••					
30034	RO	Fuse status (Ch01Ch06)			
200.40					
30040	RO	Inst V_1 (V [01500])			
30044	DO.	L . T 4 (% C F 22			
	RO		Inst T_1 (°C [-20+120]) - PT100		
30045	RO	Inst T_2 (°C [-22,0+83,0]) - on board			
30047	RO	Sum of all currents (A * 10)	Sum of all currents (A * 10)		
30048	RO	Power (KW / 10) - LSW			
30049	RO	Power (KW / 10) - MSW			
	110	Tower (IIII / 10) Morr			
30052	RO	RMS Curr Str_01 (average value on last 6 seconds)			
30053	RO	RMS Curr Str_02 (average val	lue on last 6 seconds)		
30054	RO	RMS Curr Str_03 (average val	lue on last 6 seconds)		
30055	RO	RMS Curr Str_04 (average val	lue on last 6 seconds)		
30056	RO	RMS Curr Str_05 (average val	lue on last 6 seconds)		
30057	RO	RMS Curr Str_06 (average value on last 6 seconds)			
•••					
30084	RO	RMS V_1 (V [01500]) (average value on last 6 seconds)			
•••					
30088	RO	RMS T_1 (°C [-20+120]) (average value on last 6 seconds)			
30089	RO	RMS T_2 (°C [-22,0+83,0])	(average value on last 6 seco	onds)	
•••		I			
30091	RO	,	10) (average value on last 6 s	,	
30092	RO	RMS Power (KW / 10) - LSW (average value on last 6 seconds)			
30093	RO	RMS Power (KW / 10) - MSW (average value on last 6 seconds)			

30201	RO	Firmware Version	READ ONLY		
30201	RO	SMU Model	READ ONLY		
	RO	Channels Number READ ONLY			
30203					
30204	RO	Shunt Type	READ ONLY		
30205	RO	End Scale	READ ONLY		
30206	RO	Reserved for Future Use	RFU		
30207	RO	Reserved for Future Use	RFU		
30208	RO	Reserved for Future Use	RFU		
30209	RO	Reserved for Future Use	RFU		
30210	RO	Reserved for Future Use	RFU		
30211	RO	Unique ID code [0]	READ ONLY		
30212	RO	Unique ID code [1]	READ ONLY		
30213	RO	Unique ID code [2]	READ ONLY		
30214	RO	Unique ID code [3]	READ ONLY		
30215	RO	Unique ID code [4]	READ ONLY		
30216	RO	Unique ID code [5]	READ ONLY		
•••					
40001	RW	Set up PARITY mode : 1 = None ; 2 = Ever	n ; 3 = Odd		
40002	RW	Offset Curr Str_01			
40003	RW	Offset Curr Str_02			
40004	RW	Offset Curr Str_03			
40005	RW	Offset Curr Str_04			
40006	RW	Offset Curr Str_05			
40007	RW	Offset Curr Str_06			
•••					
40034	RW	Answer Delay (msec)			
40035	RW	Time Com Active (1/10 sec.)			
40036	RW	Parity (1 = None, 2 = Even, 3 = Odd) = 40001			
40037	RW	Fuse Threshold			
40038	RW	Reversing the sign of current (Ch01Ch06)			
•••	I	T			
40040	RW	Offset V_1			
40044	DVV	Office T 4			
40044	RW	Offset T_1			
40045	RW	Offset T_2			
	DW/				
40047	RW	Minimum Current (Default = 1 A)			
40048	40048 RW Minimum Voltage (Default = 100 V)				
40052	RW	Gain Curr Str. 1			
40053	RW	Gain Curr Str_1			
40054	RW	Gain Curr Str_2			
		Gain Curr Str_3			
40055	RW	Gain Curr Str_4			
40056	RW	Gain Curr Str_5			
40057	RW	Gain Curr Str_6			

•••				
40090	RW	Gain V_1		
•••				
40094	RW	Gain T_1		
40095	RW	Gain T_2		
•••				
40101	RW	User Memory 01		
40102	RW	User Memory 02		
40103	RW	User Memory 03		
40104	RW	User Memory 04		
40105	RW	User Memory 05		
40106	RW	User Memory 06		
40107	RW	User Memory 07		
40108	RW	User Memory 08		
•••				
40201	RO	Shunt Type (= 30204)	READ ONLY	
40202	RO	SMU Model (= 30202)	READ ONLY	
40203	RO	Firmware Version (= 30201) READ ONLY		
40204	RO	Channels Number (= 30203) READ ONLY		
40205	RO	End Scale (= 30205)		
40206	RO	Reserved for Future Use RFU		
40207	RO	RO Reserved for Future Use RFU		
40208	RO	O Reserved for Future Use RFU		
40209	RO	Reserved for Future Use RFU		
40210	RO	Unique ID code [0] (= 30211) READ ONLY		
40211	RO	Unique ID code [1] (= 30212)	READ ONLY	
40212	RO	Unique ID code [2] (= 30213) READ ONLY		
40213	RO	Unique ID code [3] (= 30214)	READ ONLY	
40214	RO	Unique ID code [4] (= 30215) READ ONLY		
40215	RO	Unique ID code [5] (= 30216)	READ ONLY	

NOTES

Each "Offset Register" has 0 as default value. Each "Gain Register" has 1000 as default value. The value 1000 means x1, in this way, for example, is possible write 500 and make the value x0,5.

4.1 Memory Map Description

30001: the first two bits of these register are the mirror status of the two digital inputs on the board (INPO, INP1 on CN4). So if 30001 = 000000000000011 [bin] = 3 [dec], it means that all the two digital inputs are ON.

30002 ... 30007 : these registers contains the current value of the current reading on each channel. It is in "A / 10". If the read value is 1000 it means that the current is 100,0 A.

30034: the first six bits of 30034 show if each channel current reading is under 200 mA or not. This threshold represent the fuse status.

30040 ... **30049** : these registers show the value of some readings as the temperatures (T1 and T2), voltage reading (on connector CN3) etc...

30052 ... **30057**: these registers contains the average value on last 6 seconds of the current reading. Obviously these values are more stable than the instantaneous values show in registers 30002 ... **30007**

40001: through this register is possible set the communication parity. The default value is zero, so "no parity"

40002 ... **40007**: these are the offset registers. These registers (whose default value is 0) allow to add a constant value to the current reading. This allow to adjust a possible reading error. For example if 30002 show 230 (it means that channel CH1 read 23,0 A), writing 40002 = 15 the new value of the reading will be 30002 = 245 (it means that channel CH1 read 24,5 A).

40052 ... **40057**: these are the gain registers. These registers (whose default value is 1000) allow to multiply a constant value to the current reading. This allow to adjust a possible reading error. For example if 30002 show 230 (it means that channel CH1 read $23.0 \, \text{A}$), writing $40052 = 1500 \, \text{the}$ new value of the reading will be $30002 = 345 \, \text{(it means that channel CH1 read } 34.5 \, \text{A}$, $230 \times 1.5 = 345$).

40101 ... **40108** : these are 8 registers available to the user. They can contain data useful to the customer, for example a different progressive number for each board.

40201 : Shunt Type (= 30204) - READ ONLY

40202 : SMU Model (= 30202) - READ ONLY

40203 : Firmware Version (= 30201) - READ ONLY

40204 : Channels Number (= 30203) - READ ONLY

40205 : End Scale (= 30205) - READ ONLY

40206 ... 40209 : Not Used - Reserved for Future Use (RFU)

40210 ... 40215 : Unique device ID register (96 bits) (organized in six 16 bit words) that is unique for any board. (= 30211 ... 30216) - READ ONLY

The unique device identifier is ideally suited:

- for use as serial numbers (for example string serial numbers or other end applications).
- for use as part of the security keys in order to increase the security.

The 96-bit unique device identifier provides a reference number which is unique for any device and in any context. These bits cannot be altered by the user. The code is composed of the following parts:

```
UID [31:00] : X and Y coordinates on the wafer expressed in BCD format UID [39:32] : WAF_NUM [07:00] > Wafer number (8-bit unsigned number) UID [63:40] : LOT_NUM [23:00] > Lot number (ASCII encoded) UID [95:64] : LOT_NUM [55:24] > Lot number (ASCII encoded)
```

4.2 Reading speed

The analogic values of the currents, the voltage and the temperature are read simultaneously 10 times per second (100 msec scan time), then are inserted in it's own FIFO (a FIFO for each analogic value), 16 values deep. The value read from the board is the mobile mean of the FIFO, so it is the mean of the last 16 read values (1.6 sec), updated every 100 msec. This is done to make the analogic readout more stable and it is a good compromise between speed and readout stability.

The instant values of the analogic are temporary stored into a hidden memory area, not accessible to the COM port.

The update time depend on the speed polling time of the SCADA and the communication baud rate.


The total time requested to read the board via com port is splitted into three times: the query time, the latency time and the response time.

The query time is the time needed by the SCADA to send the MODBUS query packet and depends on the baud rate (about 4 msec at 19200 baud rate).

The latency time is the time need by the board to process the query and prepare the answer, it is between 1 and 2 msec and it is independent on the baud rate.

The response time is the time needed byte the board to send the MODBUS answer packet, it's depend on the baud rate and on the number of registers read at a time, for a single register read at 19200 baud it is about 4 msec.

So at 19200 baud rate the total time needed to read a single register is about 10 msec., you have to add 1 msec every other register read, for example to read 16 registers with a single query will take 10 msec + 15 * 1 msec = 25 msec.



5 ORDER CODES

Here below the order codes:

	CODE		DESCRIPTION
ST0HS02100\NC	ST0HS02200\NC	ST0HS02300\NC	Device with support for din rail bar
ST0HS02100\NK	ST0HS02200\NK	ST0HS02300\NK	Device without support for din rail bar
ST0HS03100\NC	ST0HS03200\NC	ST0HS03300\NC	Device with support for din rail bar
ST0HS03100\NK	ST0HS03200\NK	ST0HS03300\NK	Device without support for din rail bar
ST0HS04100\NC	ST0HS04200\NC	ST0HS04300\NC	Device with support for din rail bar
ST0HS04100\NK	ST0HS04200\NK	ST0HS04300\NK	Device without support for din rail bar
ST0HS06100\NC	ST0HS06200\NC	ST0HS06300\NC	Device with support for din rail bar
ST0HS06100\NK	ST0HS06200\NK	ST0HS06300\NK	Device without support for din rail bar

6 CONTACTS

GENERAL

Tel: 059 469978 website: www.kernelgroup.it e-mail: info@kernelgroup.it

COMMERCIAL

Sig.ra Linda Mammi Tel: 059 469978 Int. 207 e-mail: sales@kernelgroup.it Skype: mammi.kernel

ADMINISTRATION

Sig.ra Paola Morandi Tel: 059 469978 Int. 201 e-mail: amministrazione@kernelgroup.it Skype: morandi.kernel

PURCHASING and PRODUCTION

Sig. Stefano Catuogno Tel: 059 469978 Int. 204 e-mail: produzione@kernelgroup.it Skype: catuogno.kernel

TECHNICAL OFFICE

Sig. Alessandro Muratori Tel: 059 469978 Int. 205 e-mail: alessandro.muratori@kernelgroup.it Skype: muratori.kernel

Support
Tel: 059 469978 Int. 209
e-mail: support@kernelgroup.it
Skype: support.kernel

Sig. Morisi Luca e-mail: luca.morisi@kernelgroup.it Skype: morisi.kernel

Kernel Sistemi Kernel Sistemi s.r.l., via Vignolese n. 1138 41126 Modena - ITALY Tel. 059 469 978 - Fax 059 468 874 www.kernelgroup.it